



ଅଧିକ୍ଷକଙ୍କ କାର୍ଯ୍ୟାଳୟ
ଗ୍ରାମ୍ୟ ଜଳ ଯୋଗାଣ ଓ ପରିମଳ ଶୁଦ୍ଧି ବିଭାଗ
OFFICE OF THE EXECUTIVE ENGINEER
RURAL WATER SUPPLY & SANITATION DIVISION
BALANGIR

Near R.T.O. Office
Balangir, Odisha-, Pin-76700

-06652-232173 (Off)

Email: eerwss_blg@nic.i

Email: eerwssbalangir@gmail.com

Letter No. 4008 dt. 29-8-26

To

The Principal PM SHRI KENDRIYA VIDYALAYA NO 2
Shastrinagar, Balangir

Sub: - Submission of water Sample test report.

Sir,

With reference to above cited subject cited above, please find enclosed the water sample test report conducted at the District Water testing Laboratory, Balangir. The Water sample was collected from the designated source by your authorized personnel, and the analysis has been carried out based on the submitted sample

The detailed test results as per the analysis conducted, are attached herewith in Annexure-A for your reference and necessary action.

Encl: - As above.

Yours Faithfully,


28.08.26
Executive Engineer
RWS&S Division, Balangir

Memo

Date

Copy submitted to

1. The Additional Chief Engineer, Balangir for Information and necessary action
2. In-charge, State NABL Lab, RWS&S, Khandagiri, Bhubaneswar
3. The Chief Engineer, RWS&S Bhubaneswar, Odisha for information and necessary action.

Government of Odisha

P.W.A. 3—(Receipt)

Public Works Department

RECEIPT FOR PAYMENT TO GOVERNMENT

No. **P 16497** Receipt No. **P 0412425** Place Balangir
Date 20.08.2026

SION

DIVISION

Received from PM Shri Kendrya Vidyalaya No. 2

Rs. 700/- Rupees Seven hundred only

(By cheque) No 17016896

on account of Water testing fee of 1 no. of water

Sample

Cashier
or
Accountant

Signature

Designation

For Executive Engineer
R.W.S.&S. Division, Balangir

Analysis Results

Sl. No.	Block	Gp	Village	Location	Parameter	Unit	Test Method	Result	Permissible Limit (IS: 10500-2012)	Remarks
1	Balangir	Balangir	Balangir	Behind New Place, Shastrinagar, Balangir	pH	-	IS 3025 (Part 11):1983	7.3	8.5	
					Total Dissolved Solids (TDS)	mg/L	IS 3025 (Part 16):1984	140	2000	
					Turbidity	NTU	IS 3025 (Part 10):1984	0.12	5	
					Chloride (Cl ⁻)	mg/L	IS 3025 (Part 32):1988	14	1000	
					Fluoride (F ⁻)	mg/L	IS 3025 (Part 23):1986	0.36	1.5	
					Total Hardness as CaCO ₃	mg/L	IS 3025 (Part 21):1983	38	600	
					Iron (Fe)	mg/L	IS 3025 (Part 53):2003	0.1	1	
					Alkalinity	mg/L	APHA, 23rd Ed. 2017-2320 B (Titration Method) 2017	28	600	

Shyams
28.8.26
Lab. Assistant

Divisional Laboratory, RWS&S Balangir

M. K. S. S.
28.08.26
Lab. Chemist

Divisional Laboratory, RWS&S Balangir

[Signature]
28.8.26
Executive Engineer
RWS&S Division, Balangir

M. K. S. S.
28.08.26