

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. PHEDA-2705

Dated: 22-8-2025

It is certified that an inspection team headed by Rohit Mehra (7.0)

(Name of Officers with designation) from PHC Akhnour PHED

inspected the PM Shri KV Jaurian

(Name & Address of the school) on 11-04-25 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. 750/SL/558 dated 11-04-25

of State water testing lab (PHED Lab) certified that the

PM Shri KV Jaurian (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the

hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till 15-04-26

Signature with Seal: [Signature] OFFICER (AEE)

Name

Designation

Name & Address of the Office / Department: PHC KV Jaurian

To PM Shri KV Jaurian
Vill Dhok Khalea, Jaurian
(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies



STATE WATER TESTING LABORATORY, JAL BHAWAN, NARWAL, JAMMU
JAL SHAKTI (PHE) DEPARTMENT, JAMMU, UT OF J&K
DOC Ref: PHE/WQC/SL/QF-7.8-01



TEST REPORT

Customer Name:	KENDRIYA VIDYALAYA JOURIAN		
Customer Ref No:	—		
Sample Quantity:	2 litres	Sample Container Condition:	OK / Not Satisfactory
Sample ID:	JSD/SL/558	Date of Receipt:	11-04-2025
Report No:	558	Report Date:	15-04-2025
Sample Details:	K.V Jaurian, Akhnour, Jammu. (18/202)		Source: Borewell
Test Start Date:	11/04/2025	Test End Date:	12/04/2025
Sample Collected by	Haneez Khan		

Sr. No.	Parameter	BIS Permissible Limit	Unit	Test Results	Remarks
1.	pH	6.5-8.5	—	7.13 @ 25°C	Fit
2.	Colour	15	HU	10	Fit
3.	TDS	2000	mg/l	188	Fit
4.	Turbidity	5	NTU	0.55	Fit
5.	Iron	1.0	mg/l	0.02	Fit
6.	Chloride	1000	mg/l	1.99	Fit
7.	Magnesium	100	mg/l	7.77	Fit
8.	Sulphate	400	mg/l	4.99	Fit
9.	Calcium	200	mg/l	51.30	Fit
10.	Total Hardness	600	mg/l	160.0	Fit
11.	Alkalinity	600	mg/l	150.0	Fit
12.	Nitrate	45	mg/l	12.99	Fit
13.	Fluoride	1.5	mg/l	0.08	Fit
14.	Arsenic	0.01	mg/l	N.D	Fit
15.	Ammonia	0.5	mg/l	<0.5	Fit
16.	E-Coli	Absent	CFU	Absent	Fit

Note:

- The test report and result relate to the material's specimen/ sample (s) as delivered /received and tested in the laboratory.
- This test report shall not be reproduced in part, without the permission of this laboratory.
- Any correction invalidates this test report.
- Results apply to the sample as received.

Reviewed by: Rohit Shrivastava
(Mr/Ms: Rohit Shrivastava)
Designation: Chemist

Authorised Signatory
[Signature]
Assistant Executive Engineer
(Chief Chemist)
State Water Testing Lab Jammu